

Enforcement Orders Signed July 14, 2015

Fountain Bleu Apartments/Corpus Christi, Docket No. GUD 10225

System (961181), Nueces County

Rules violated:

Violation No. 1

Requirement: Title 16, 8.215 (e)(3)

Quarterly malodorous concentration tests were not conducted or records retained for two (2) years for gas odorized by the supplier or that contained natural malodor.

Note: Quarterly odorization tests had not been performed and documented since February 8, 2012 and had not been conducted at any time prior to February 8, 2012.

Violation No. 2

Requirement: 49 CFR 192.603(b)

Records necessary to administer the operation and maintenance plan were not maintained or were inadequate.

Note: The operator could not provide a record of the over pressure protection inspection record from their supplier for 2011 or 2012.

Violation No. 3

Requirement: 49 CFR 721-001

Distribution mains were not patrolled as often as necessary to observe conditions affecting public safety.

Notes: Quarterly patrolling of the gas pipeline system had not been performed and documented since February 8, 2012 and not been conducted at any time prior to February 8, 2012.

Violation No. 4

Requirement: 49 CFR 192.605(a)

There was no written operation and maintenance plan.

Penalty paid: \$12,500.00