

## **Enforcement Orders Signed June 9, 2015**

### **City of Corpus Christi, Docket No. GUD 10415**

System (710174), Nueces County

Rules violated:

#### **Violation No. 1**

Requirement: 49 CFR 192.615(a)

Violation Code: The written emergency plan did not include adequate procedures for the following item(s):

- a) receiving, identifying, or classifying notices of events requiring an immediate response.
- b) establishing or maintaining communication with fire, police, or other public officials.
- c) prompt and effective response to a notice of each type of gas emergency
- d) availability of personnel, equipment, tools or materials as needed at the emergency scene
- e) actions to protect people first
- f) emergency shutdown and pressure reduction in any section of the system
- g) making safe any actual or potential hazard to life or property
- h) notifying appropriate fire, police, or other public officials of gas p/l emergencies & coordinating both planned & actual responses during an emergency.
- i) safely restoring service outages
- j) beginning investigative action as soon as possible after the emergency

Location: 6200 Saratoga Blvd

Note: Operator did not have an effective response to a fire directly involving their pipeline and therefore did not take the appropriate steps to prevent accidental ignition.

**Penalty paid:** \$2,500.00