

Enforcement Orders Signed July 14, 2015

Amerigas Propane, LP, Docket No. GUD 10325

Oak Hill Subdivision/System (511917), Montgomery County

Rules violated:

Violation No. 1

Requirement: Title 16, 8.105 (1) and (3)

Records were either not maintained or not adequate for activities that may be required by 49 CFR, Parts 191, 192, 193, or 199, or Title 16, 8.215 (odorization).

Location: Oak Hill Subdivision, Pinehurst, Texas

Note: During the pipeline safety evaluation performed by Pipeline Safety staff on the Oakhill Subdivision system it was found that AmeriGas Propane did not retain records of compliance for certain activities required to be performed by CFR 192. These are: Cathodic Protection Annual Monitoring: CY2012- 2013 Odorant Level Test: CY2012-2013 Distribution Main Patrolling: CY2012-2013 Distribution System Leakage Survey: CY2010- 2013

Penalty paid: \$2,500.00