

Enforcement Orders Signed April 8, 2015

City of Alto, Docket No. GUD 10403

System #310017

Rules violated:

Violation No. 1

Requirement: 49 CFR 192.603(b)

Records necessary to administer the operation and maintenance plan were not maintained or were inadequate.

Violation No. 2

Requirement: Title 16, 8.207(c)(1)

A Grade 2 leak was discovered and the operator did not re-evaluate the leak at least once each 30 days until the leak was repaired or cleared.

Violation No. 3

Requirement: Title 16, 8.207(c)(2)

A Grade 2 leak was discovered and the operator did not repair the leak within six months of its detection.

Violation No. 4

Requirement: Title 16 8.210(e)

The operator did not submit leak reports using the Commission's online reporting system, Form PS-95, by July 15 and January 15 of each calendar year.

Penalty paid: \$2,500.00