

# Enforcement Orders Signed March 21, 2017

## Texas Country View Properties LP

### Docket No. GUD 10463

System Name: Country View Estates MHP (System id 660128)

#### #1 Violation Code: 49 CFR 192.809(a)

The operator did not have a written qualification program by April 27, 2001.

Description: Operator Qualification

Location: 1006 N Hwy 377, Roanoke, TX 76262

Comment: There was no written qualification program available, as at the date of inspection. Note that individuals performing covered tasks must be qualified to satisfy this violation and date of qualification must be verifiable for each individual along with the plan.

#### #2 Violation Code: 49 CFR 192.625(f)(1)

Written verification that the master meter gas system had the proper concentration of odorant was not obtained from the gas supplier where periodic "sniff" tests were conducted.

Description: Odorization Verification Letter

Location: 1006 N Hwy 377, Roanoke, TX 76262

Comment: Written verification that, the master meter gas system had the proper concentration of odorant was not obtained from the gas supplier,

A verification letter can be obtained from:  
Atmos Energy, James Doyle  
Telephone Number:  
254-722-7874

#### #3 Violation Code: 16 TAC 8.51 (b)

The master meter operator did not have on file with the Commission an approved organization report Form P-5.

Comment: There was no record of the operator's "Form P-5 (Organization Report)" filing with the commission. Statewide Rule 1 requires every entity performing operations within the jurisdiction of the commission's oil & gas division (including master meter operators) to maintain an active Form P-5 with the commission. For P-5 inquiries & assistance, please contact, The Railroad Commission of Texas, P-5 Assurance Division, P.O. Box 12967, Austin, TX 78711 or Telephone: 512-463-6772 or 512-463-6743

AGREED ORDER SIGNED: 3/21/2017

PENALTY PAID: \$750.00