

Enforcement Orders Signed April 4, 2017

DCP Midstream, LP

Docket No. GUD 10586

System Name: Red Bluff Lake Pipeline (System ID #963891)

Item # 1

Violation Code: 49 CFR 192.465 (a) – The cathodic protection system at the listed location(s) has not been monitored at least once each calendar year, within intervals not exceeding 15 months.

Location: Red Bluff Lateral

AGREED ORDER SIGNED: 4/4/17

PENALTY PAID: \$5,000.00