

# Enforcement Orders Signed May 10, 2017

## Trinity Village

### Docket No. GUD 10482

System Name:

560557	700 TRINITY VILLAGE
562467	600 TRINITY VILLAGE
2095	SYSTEM OF COMPANY ID 7327

**System Name: 700 TRINITY VILLAGE**

**Evaluation: 20153005**

Item No	Requirement	Description	Location
10	Title 16, 8.225 (c)	The operator of a natural gas pipeline system with plastic pipe installed did not file the Plastic Pipe Inventory on Form PS-81 with the Commission by March 15.	Master Meter

**System Name: 600 TRINITY VILLAGE**

**Evaluation: 20153006**

Item No	Requirement	Description	Location
1	49 CFR 192.739(a)	<p>Each pressure limiting station, relief device (except rupture discs), and pressure regulating station and its equipment must be subjected at intervals not exceeding 15 months, but at least once each calendar year, to inspections and tests to determine that it is:</p> <ol style="list-style-type: none"> <li>1. in good mechanical condition.</li> <li>2. adequate from the standpoint of capacity and reliability of operation for the service in which it is employed.</li> <li>3. set to control or relieve at the correct pressure consistent with the pressure limits of 192.201(a).</li> <li>4. properly installed and protected from dirt, liquids, or other conditions that might prevent proper operation.</li> </ol>	Master Meter

