

Enforcement Orders Signed September 16, 2014

Atmos Energy Corp., Mid-Tex Division

Docket No. GUD 10307

System Name:

San Angelo (System id 211132)

Violation: 16B-105-001 - Records were either not maintained or not adequate for activities that may be required by 49 CFR, Parts 191, 192, 193, or 199, or Title 16, 8.215 (odorization).

Location: DRS 75 - North of Hwy. 67 east of North Adams.

Note: A regulator inspection records review was conducted of the referenced Regulation Station. Records indicated an inspection was conducted on 10-19-12, subsequently, a field review was conducted of the regulator and revealed the regulator was removed. A records review was then conducted of the removal and indicated it had been removed on 8-23-12 prior to it's inspection date.

**Agreed order signed 9/16/14 - penalty amount paid \$28,500