

Enforcement Orders Signed January 23, 2019

GUD 10630

MCK Enterprises

System Name: Stephens Court Apartments

System ID No.: 361581

1. Title 16, 8.51(b)
Alleged Violation Code: 16B-051-002: The master meter operator did not have on file with the Commission an approved organization report Form P-5.
16 TAC Ch. 8; Table 1, 16 TAC §8.51-Organization Report
2. Title 16, 8.201(c)(1)
Alleged Violation Code: 16C-201-004: The annual pipeline safety program fee assessed by the Commission for each natural gas master meter system has not been received.
16 TAC Ch. 8; Table 1, 16 TAC §8.201-Pipeline Safety and Regulatory Program Fees
3. 49 CFR 192.479(a)
Alleged Violation Code: 192-479-006: Each pipeline or portion of pipeline exposed to the atmosphere was not cleaned and coated.
16 TAC Ch. 8; Table 1, 49 CFR 192 Subpart I- Requirements for Corrosion Control
4. 49 CFR 192.625(f)(1)
Alleged Violation Code: 192-625-004: Written verification that the master meter gas system had the proper concentration of odorant was not obtained from the gas supplier where periodic "sniff" tests were conducted.
16 TAC Ch. 8; Table 1, 49 CFR 192.625-Odorization of gas
5. Title 16, 8.235 (b)(1)-(4)
Alleged Violation Code: 16C-235-001: The operator or operator's representative did not make an effort to conduct community liaison activities by means of a telephone conference or by certified mail with fire, police, and other appropriate public emergency response officials as required in 16 TAC 8.235 (c)(1) and (2) when a meeting in person could not be arranged.
16 TAC Ch. 8; Table 1, 16 TAC §8.235-Natural Gas Pipelines Public Education and Liaison
6. 49 CFR 192.605(a)
Alleged Violation Code: 192-605-012: The operator had not reviewed and updated the operations and maintenance manual at intervals not exceeding 15 months, but at least once each calendar year.
16 TAC Ch. 8; Table 1, 49 CFR Part 192-Transportation of Natural and Other Gas by Pipeline
7. 49 CFR 192.616(j)
Alleged Violation Code: 192-616-012: The master meter or petroleum gas system did not provide public awareness messages twice annually to its customer and or property owners adjacent to the gas system.
16 TAC Ch. 8; Table 1, 49 CFR Part 192-Transportation of Natural and Other Gas by Pipeline

8. 49 CFR 192.1015(a)

Alleged Violation Code: 192-MIM-101: The Distribution Integrity Management Plan was not written and implemented per the requirement of 192.1015 by 08/02/2011, OR For a gas system put into service, or acquired after 08/02/2011, a plan was not written and implemented prior to beginning of operating.
16 TAC Ch. 8; Table 1, 49 CFR 192, Subpart P- Gas Distribution Pipeline Integrity Management

Penalty collected: \$5,000.00