

Enforcement Orders Signed October 30, 2018

GUD 10723

Company: CITY OF SEALY

Begin Date: 02/12/2018

End Date: 02/16/2018

Lead Inspector: Kennedy Kiprotich

Phone Number:

System Name: SYSTEM OF COMPANY ID 0336

Evaluation: 20180211

- | | | | |
|----|------------------------|---|-----------|
| 9 | Title 16, 8.230 (b)(1) | The natural gas supplier to a school facility did not have procedures for receiving written notice from a person responsible for a school facility specifying the date and result of each test of school piping. | sealy, TX |
| 11 | 49 CFR 192.739(a) | Each pressure limiting station, relief device (except rupture discs), and pressure regulating station and its equipment must be subjected at intervals not exceeding 15 months, but at least once each calendar year, to inspections and tests to determine that it is:

1. in good mechanical condition.

2. adequate from the standpoint of capacity and reliability of operation for the service in which it is employed.

3. set to control or relieve at the correct pressure consistent with the pressure limits of 192.201(a).

4. properly installed and protected from dirt, liquids, or other conditions that might prevent proper operation. | Sealy, TX |

Penalty collected: \$4,000.00