

Enforcement Orders Signed August 21, 2018

ATMOS PIPELINE – TEXAS

Docket No. GUD 10689

Company: ATMOS PIPELINE - TEXAS

Begin Date: 11/16/2017

End Date: 12/16/2017

Lead Inspector: Michael Parker

Phone Number:

System Name: 038-1

Evaluation: 20173497

Item No	Requirement	Description	Location
1	49 CFR 192.605(a)	The operator did not prepare and/or follow for each pipeline, a manual of written procedures for conducting operations and maintenance activities and for emergency response.	3005 NW Loop 286 Paris, TX

Penalty collected: \$11,000.00